# DRINKING WATER NOTICE

# Apple Creek Village PWS

## Significant Deficiency/Treatment Technique Requirements

The Ohio EPA has identified, through the sanitary survey site visit on September 18th and October 10, 2019, a significant deficiency associated with the public water system. The Apple Creek Village PWS did not comply with establishing a public water system valve exercising program by December 31, 2020.

**What should I do?**

- **There is nothing for you to do at this time.**

**What does this mean?**

- This situation does not require that you take immediate action. If it had been, you would have been notified immediately.

**What happened? What is being done?**

- We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact Cheryl Drew (name of contact) at 330-698-5462 (phone number) and/or 63 E Main St, PO Box 208, Apple Creek OH 44606 (mailing address)

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID#: OH8500112 Date distributed: 2/26/2021

Tier 2: Treatment Technique Violation (Significant Deficiency type 45/FC)